

Ste. Genevieve County Health Department

(573) 883-7411

Fax (573) 883-5857

115 Basler Dr.

Ste. Genevieve, MO 63670

SEPTIC TANK WATERTIGHT TEST

Method: Tanks shall be watertight tested in the field. The test shall be performed by filling the tank two inches (2") above the riser inlet. At the end of the first twenty-four (24) hour period, the tank water level should be refilled. After another twenty-four (24) hour period, no more than one inch (1") of water should have dropped from the original reading.

Application Number: _____

Permit Number: _____

Date of first filling tank: _____ Time of filling: _____

Date of second filling of tank: _____ Time of filling: _____

Twenty-four hour later water level drop: _____ Time of checking _____

I, _____, a registered installer, registration # _____
have performed the watertight test according to the above-mentioned method.

Installers Signature: _____

Date: _____