



MISSOURI DEPARTMENT OF HEALTH AND SENIOR SERVICES
 BUREAU OF ENVIRONMENTAL HEALTH SERVICES
 ONSITE WASTEWATER TREATMENT PROGRAM
APPLICATION FOR VARIANCE

PLEASE PRINT			
APPLICATION NUMBER			COUNTY
PROPERTY OWNER (FIRST NAME MI LAST)			
SITE ADDRESS	CITY	STATE MO	ZIP CODE
MAILING ADDRESS (IF DIFFERENT)	CITY	STATE	ZIP CODE
TELEPHONE NUMBER	ALTERNATE TELEPHONE NUMBER	FAX NUMBER	
YEAR LOT WAS PLATTED		YEAR EXISTING SYSTEM WAS CONSTRUCTED	
SYSTEM IS <input type="checkbox"/> New Construction <input type="checkbox"/> System Replacement <input type="checkbox"/> System Repair <input type="checkbox"/> System Expansion			
LIST REQUESTED VARIANCE(S) SEPARATELY; CHECK THE APPROPRIATE BOX AND COMPLETE DETAILS.			
<input type="checkbox"/> UNABLE TO COMPLY WITH MINIMUM SETBACK DISTANCE(S) REQUIRED BY RULE:			
DISTANCE FROM PART OF SYSTEM	SITE FEATURE	SHOULD BE	REQUESTED SETBACK
TO		FEET;	FEET
TO		FEET;	FEET
TO		FEET;	FEET
TO		FEET;	FEET
<input type="checkbox"/> UNABLE TO COMPLY WITH THE MINIMUM SEPARATION DISTANCE REQUIRED BY RULE BETWEEN THE ABSORPTION TRENCH BOTTOM, OR DRIP EMITTERS, AND:		(BEDROCK OR OTHER RESTRICTIVE FEATURE)	
VERTICAL SEPARATION DISTANCE SHOULD BE		REQUESTED SEPARATION IS	
INCHES		INCHES	
<input type="checkbox"/> UNABLE TO COMPLY WITH THE MINIMUM SOIL TREATMENT (ABSORPTION) AREA REQUIRED BY RULE:			
TREATMENT AREA SHOULD BE		REQUESTED ACTUAL TREATMENT AREA IS	
SQ. FT.		SQ. FT.	
HOW WILL THE SYSTEM PROTECT PUBLIC HEALTH, DRINKING WATER, GROUNDWATER, AND SURFACE WATER?			
PROVIDE NAME(S) AND MAILING ADDRESS(ES) OF POTENTIALLY AFFECTED ADJACENT PROPERTY OWNER(S). ATTACH, WITH A SITE LAYOUT DIAGRAM, TO YOUR ONSITE SEWAGE SYSTEM CONSTRUCTION PERMIT APPLICATION.			
ATTENTION PROPERTY OWNER'S STATEMENT: By signing this application I/we are requesting the variance(s) listed above and I/we acknowledge and agree: If approved, the variance(s) will reduce the normally required separation distances and/or size of the onsite wastewater treatment system. This proposed system must be operated properly and receive regular maintenance to insure it will protect health and the environment. I/we agree to properly operate and maintain the system and to comply with all conditions of variance and permit approval.			
PROPERTY OWNER'S SIGNATURE	DATE	PROPERTY OWNER'S SIGNATURE	DATE



MISSOURI DEPARTMENT OF HEALTH AND SENIOR SERVICES
 BUREAU OF ENVIRONMENTAL HEALTH SERVICES
 ONSITE WASTEWATER TREATMENT PROGRAM
APPLICATION FOR VARIANCE

19 CSR 20-3.060(1)(D) TABLE 1-MINIMUM SET-BACK DISTANCES

Minimum Distance From	Sewage Tank ¹ (ft)	Disposal Area ² (ft)	Lagoons (feet)
Private water supply well ³	50	100	100
Public water supply well	300	300	300
Cistern	25	25	25
Spring	50	100	100
Classified stream, lake or impoundment*	50	50	50
Stream or open ditch ⁴	25	25	25
Property lines	10	10**	75
Building foundation	5	15	15[100]
Basement	15	25	25[100]
Swimming pool	15	15	15
Water line under pressure	10	10	10
Suction water line	50	100	100
Upslope interceptor drains	-	10	10
Downslope interceptor drains	-	25	25
Top of slope of embankments or cuts of two feet (2') or more vertical height	-	20	20
Edge of surficial sink holes	50	100	500
Other soil absorption system except repair area	-	20	20

* A classified stream is any stream that maintains permanent flow or permanent pools during drought periods and supports aquatic life.

** Recommend twenty-five feet (25') of downslope property line initially, but repair may be allowed to ten feet (10') of downslope property line.

- 1 Includes sewage tanks, intermittent sand filters and dosing chambers.
- 2 Includes all systems (sand filter, wetland and the like) except wastewater stabilization ponds.
- 3 Unplugged abandoned wells or wells with less than eighty feet (< 80') of casing depth shall have one-hundred- fifty feet (150') minimum distance from all above.
- 4 Sewage tanks and soil absorption systems should never be located in the drainage area of a sinkhole. [The minimum setbacks for lagoons are 100 feet from the residence it serves and 200 feet from other existing residences.]

One site/soil limitation for onsite wastewater treatment systems (OWTS) is vertical separation. Vertical separation is defined as the distance between the absorption trench bottom and a limiting condition, such as a seasonal high water table, bedrock or a restrictive horizon. Vertical separation requirements are in place to ensure a zone of at least provisionally suitable, unsaturated soil to adequately renovate the applied wastewater before it is recycled into groundwater or surface waters. The table below summarizes the minimum vertical separation requirements.

VERTICAL SEPARATION TABLE		
TYPE of SYSTEM	SITE/SOIL LIMITATION or CHARACTERISTIC	VERTICAL SEPARATION (FEET)
CONVENTIONAL		2
	Rapid percolation	4
	Cherty clays in areas of concern for groundwater	4
Serial		3
Dosed D-box		2
Shallow placement		2
LPP		1
	Areas of concern for groundwater	4
DRIP		1
SAND MOUND		2
	Groundwater contamination potential	4
LAGOON	Crevised bedrock	3
	Or a minimum clay liner thickness of:	1